

5/28/2026 2:21:34 PM

WORK ORDER

Chad Reidlinger d/b/a CRRS Creative Services LLC

530 Mountain Trace
Cherry Log, GA 30522
(954) 868-6279

Customer #: 206041
Order #: 506166
Location #: 282202
Zone: B-010-THU-
Terms: Net 30

Map Code:

Tech:

Service Code: Propane Service

Description: 5/29/26 T/I 250AG W/200G@2.499G LEFT SIDE OF HOUSE.
RUN YD LINE, RUN LINE FOR STOVE C/C STOVE, RUN LINE
FOR FIREPLACES - T/I 2 24" Sasatras with VFSR - T/I 1 Carol
Rose Wildwood - T/I 3 WALL TIMERS CALL 954-868-6279 -
CCOF - CT - T/I Monitor for auto

Date Ordered:	Scheduled Date:	Est. Completion:	Start:	Stop:
---------------	-----------------	------------------	--------	-------

Name:

Last Service:

Last Tune Up:

Contact:

SC Renewal:

Manufacturer:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------

✓



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206041

Date: 5/29/26

Name: CHAD REIDLINGER DBA CRRS CREATIVE SERVICES

Instructions: T/I 250AG W/200G @ 2,499 RUNYD LINE
LINE TO STOVE C/C STOVE LINE TO 2X F/P T/I 2 WALL

Address: 530 MOUNTAIN TRACE

TIMERS T/I 24" SASS T/I 24" CAROL ROSE WILDWOOD

CHERRY LOG GA 30522

Order #506166

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components and cannot be construed to cover future or unforeseen happenings

Appliance Check:

Appliance	Log Set	Log Set	Log Set
Manufacturer	ever warm	ever warm	cooktop ketchenaid
Model #	2096826560	2096826560	h/c 6D506555
Serial #	2508P40491	2508P404990	D50102023
Burner/Combustion Chamber	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Sediment Trap	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Combustion Air	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Taken Out of Service	☐ Yes ☒ No	☒ Yes ☒ No	☐ Yes ☒ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M1441812	good	Trinity	2014	AS	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	RC30	3403TR1 2026	☒ Correct ☐ Incorrect		
2nd	RC30	3403B4 10D23	☒ Correct ☐ Incorrect	11.2	12.1

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass
120 PSI	120 PSI	10 Mins	☒ Yes ☐ No
WC	WC	Mins	

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass
15 PSI	15 PSI	10 Mins	☒ Yes ☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items that

- ☐ I have informed the service technician of all gas-burning appliances, gas lines and unused piping not connected to any gas appliance on my property
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder
- ☐ I have smelled propane gas and can detect its odor
- ☐ I have been told to consider installing one or more gas detectors
- ☐ I have received safety information and told to read it and share it with all family members
- ☐ I am satisfied with the service work performed.

Service Technician (Print) Dillon Payne	Service Technician (Signature) Dillon Payne	Date 5/29/26
Customer (Print)	Customer (Signature)	Date

CNP



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: **206041**

Date: **5/29/26**

Name **CHAD REIDLINGER D.B.A CRRS CREATIVE SERVICES** Instructions: **T/I 250AG W/200G @2.499 LEFT SIDE OF**
Address **530 MOUNTAIN TRACE** **HOUSE RUN YD LINE-LINE FOR STOVE&C/C STOVE RINE LINE**
CHERRU LOG GA 30522 **2X F/P T/I 24" SASS W/VFSR T/I CAROL ROSE WILDWOOD 24"**
Order # **506166** **T/I 2 WALL TIMERS**

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to _____ year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$

\$

Standard Vent Kit \$

\$

Standard Install \$

\$

Total \$

\$

Tank Set

New Cust Special

L P Gas /Gal **2.999**

L P Gas /Gal **2.499**

Gallons **200**

Gallons **200**

FRCC \$9.79

FRCC \$9.79

9.79

Fuel Total **758.19**

Fuel Total **545.26**

545.26

Tank Lease/YR **99.00**

1st yr Lease **FREE**

FREE

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250

Tank Set Fee **20.00**

20.00

Safety Inspection \$129.95

\$29.95

29.95

Total Labor

Total charges

Prepay Bal On Account

Safe Appliance Savings

543.28

Safe Appliance Rebate 50.00

TOTAL BALANCE DUE