

Scott

2

5/26/2026 10:20:22 AM

WORK ORDER

Kevin Moody

1902 Highway 382W
Ellijay, GA 30540
(404) 456-2823

Customer #: 200343
Order #: 507073
Location #: 275105
Zone: B-042-TUE-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 06/01/26 - Run new gas line to stove in laundry room through
the crawlspace approx. 10ft and H/U. Call: 404-456-2823 CCOF
- JB

Date Ordered: 5/26/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:

Last Service: 6/27/2025

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 200343

Date 6/01/26

Name: KEVIN MOODY - RESIDENCE

Instructions: RUN NEW LINE TO GAS STOVE THROUGH THE
CRAWLSPACE TO THE LAUNDRY ROOM AND H/U. CCOF-JB
404- 456-2823

Address: 1902 HIGHWAY 382W

Order #: 507073

ELLIJAY, GA 30540

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	5700					
Manufacturer	Viking					
Model #	V6C3224B5501					
Serial #	172225C10096732					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	MAF-1-522	Good	AKOSA	2023	A:	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rejo	3403/187	☒ Correct ☐ Incorrect		
2nd	Rejo	4403/4	☒ Correct ☐ Incorrect	11.3	13.2

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
12.0 PSI	10.0 PSI	10 Mins	☒ Yes ☐ No	15 PSI	15 PSI	10 Mins	☒ Yes ☐ No
WC	WC	Mins					

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	William Taylor	Service Technician (Signature)	William Taylor	Date	6/1/26
Customer (Print)		Customer (Signature)		Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 200343
Name KEVIN MOODY
Address 1902 HWY 382W
ELLIJAY GA 30540

Date: 5-14-26
Instructions: PICK UP 250 AG DROP OFF 325U
W/50G THEY WILL BURY. CCOF JB 404-456-28
Order #: 514122 23

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai	\$	\$
Standard Vent Kit	\$	\$
Standard Install	\$	\$
Total	\$	\$

Tank Set

New Cust Special

L.P. Gas /Gal	2.999	L.P. Gas /Gal	2.999
Gallons	50	Gallons	50
FRCC	\$9.79	FRCC	\$9.79
Fuel Total	299.90	Fuel Total	299.90
Tank Lease/YR	129.00	1st yr Lease	129.00

Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee	\$250	Tank Set Fee 20.00
Safety Inspection	\$129.95	\$29.95
Total Labor		
Total charges		
Prepay Bal On Account		

Safe Appliance Savings	350.00
Safe Appliance Rebate	50.00

TOTAL BALANCE DUE