

6/8/2026 4:20:12 PM

WORK ORDER

Miles Johnson

Scenic Drive
Blue Ridge, GA 30513
(706) 455-8878

Customer #: 206191
Order #: 514187
Location #: 282407
Zone: B-009-WED-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 6/12/26 T/I 250 Temp Tank w/50G @ 2.499 Run line to F/P,
stove and W/H Run yard line T/I 36" Grey Monessen Firebox
Call 706-455-8878 CCOF-CLT

Date Ordered: 6/8/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------------	------------------------	-------------------------	---------------	--------------

Name:

Last Service:

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206191

Date: 6/12/26

Name: MILES JOHNSON

Address: SCENIC DRIVE

BLUE RIDGE GA 30513

Instructions: T/I TEMP TANK W/50G @2,499. RUN LINES
TO F/P STOVE W/H RUN YD LINE T/I GRY 36" MONESSEN
FIREBOX CCOF CLT

Order #: 514187

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Water heater					
Manufacturer	Rinnig					
Model #	Reh-VG2528FE4D-45					
Serial #	PACA 01/378					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M1350492	Good	Rinnig	2013	AJ	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	RC90	3403T89	☒ Correct ☐ Incorrect		
2nd	RC90	440344	☒ Correct ☐ Incorrect	11.2	12.9

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
105 PSI	105 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Ollan Payne	Service Technician (Signature)	Ollan Payne	Date	6/12/26
Customer (Print)		Customer (Signature)		Date	

CNP



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #206191

Name MILES JOHNSON

Address SCENIC DRIVE

BLUE RIDGE GA 30513

Date: 6/12/26

Instructions: T/I 250 TEMP TANK W/50G @2.499 RUN
LINE TO F/P STOVE W/H AND YD LINE T/I 36" GRY MONESS.

FIREBOX CCOF

Order #: 514187

CLT

DESCRIPTION OF WORK

COMMENTS: Installed Rinnai 7.5 and Roughed in for system

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
6-12	9:30	1:00	3.5 - 1.5 = 2	100.00/hr	200
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank 20

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

* I have received the Consumer Safety information & material.

* I am satisfied with the work performed.

* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.

* Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$	\$
Standard Vent Kit \$	\$
Standard Install \$	\$
Total \$	\$

Tank Set

New Cust Special

L.P. Gas /Gal 2.999	L.P. Gas /Gal 2.499
Gallons 50	Gallons 50
FRCC \$9.79	FRCC \$9.79
Fuel Total 276.85	Fuel Total 144.17
Tank Lease/YR 99.00	1st yr Lease FREE
Total Materials	577.96
Sub-Total	
Sales Tax	390.63
Tank Set Fee \$250	Tank Set Fee 20.00
Safety Inspection \$129.95	\$29.95
Total Labor	200
Total charges	
Prepay Bal On Account	

Safe Appliance Savings 494.52

Safe Appliance Rebate 200.00

TOTAL BALANCE DUE

6170.09