

WORK ORDER

William Bruce

119 Hidden Acres
Mineral Bluff, GA 30559
(941) 400-7566

Customer #: 206175
Order #: 514516
Location #: 251510
Zone: B-014-WED-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 06/15/26 - T/I RX199 W/HEATER. HAUL OFF OLD UNIT - PER
MIKE - CALL 941-700-7566 - CCOF - CT

Date Ordered: 6/10/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
Name: Heating System	Last Service:	Last Tune Up:		
Contract:	SC Renewal:			
Manufact:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206175

Date: 6-15-26

Name: WILLIAM BRUCE

Instructions: T/I RX199 W/ HEATER HAUL OFF OLD
UNIT PER MIKE CCOF CT 941-700-7566

Address: 119 HIDDEN ACRES

Order #: 514516

MINERAL BLUFF GA 30559

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	water heater					
Manufacturer	Rinnai					
Model #	RX199i					
Serial #	Sh 30-132697					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
325	254018751	Good	American	1994	Ag	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Med	1122 H	☒ Correct ☐ Incorrect		
2nd	Rego	4403	☒ Correct ☐ Incorrect	11.1	12.8

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
120 PSI	120 PSI	10 Mins	☒ Yes				☐ Yes
			☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Alex Cash	Service Technician (Signature)		Date	
Customer (Print)	WM Bruce	Customer (Signature)		Date	6/15/26



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206175
Name WILLIAM BRUCE
Address 119 HIDDEN ACRES
MINERAL BLUFF GA 30559

Date: 6-15-26
Instructions: T/I RX199 W/ HEATER HAUL OFF OLD UNIT
PER MIKE 941-700-7566 CCOF CT
Order #: 514-516

DESCRIPTION OF WORK

COMMENTS: Installed Rinnai, RX199, Haul off old unit.

SERVICED BY: ALICE

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
	<u>9:00</u>	<u>1:00</u>	<u>1.5 HR</u>	<u>100.00/HR</u>	
			<u>4 HR - 1.5 HR</u>	<u>100.00/hr</u>	<u>250.00</u>

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank 55

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price		Contract Price	
RX199 Rinnai	\$2473.00	\$ 2559.95	
Standard Vent Kit	\$526.95	\$ 0.00	
Standard Install	\$450.00	\$ 0.00	
Total	\$3449.95	\$ 2559.95	2559.95
Tank Set		New Cust Special	
L.P. Gas /Gal		L.P. Gas /Gal	
Gallons		Gallons	
FRCC	\$9.79	FRCC	\$9.79
Fuel Total		Fuel Total	
Tank Lease/YR		1st yr Lease	
Total Materials			
Sub-Total			<u>2834.85</u>
Sales Tax			<u>179.15</u>
Tank Set Fee	\$250	Tank Set Fee	
Safety Inspection	\$129.95		\$29.95
Total Labor			<u>250.00</u>
Total charges			
Prepay Bal On Account			
Safe Appliance Savings			890.00
Safe Appliance Rebate			<u>400.00</u>
TOTAL BALANCE DUE			<u>3014.15</u>