

6/16/2026 9:05:08 AM

WORK ORDER

Robert Rogers

138 Patrick Point
Blairsville, GA 30512
(706) 897-0962

Customer #: 206208
Order #: 515363
Location #: 282431
Zone: B-002-MON-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 6-18-26 Run yard line and connect to tank. 706-897-0962 CCOF
SM

Date Ordered: 6/16/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
Name:	Last Service: 6/15/2026	Last Tune Up:		
Contract:	SC Renewal:			
Manufact:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 205208

Date: 6-18-26

Name: ROBERT ROGERS

Instructions: RUN YARD LINE AND CONNECT TO T
TANK CCOF SM 706-897-0962

Address: 138 PATRICK POINT
BLAIRSVILLE GA 30512

Order #: 515262

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	furnace					
Manufacturer	tempest					
Model #	EAM5X37M17A1E					
Serial #	J260311194					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	m2504386	Good	TRC	2025	UG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	MCC	25 MAR 24	☒ Correct ☐ Incorrect		
2nd	REGO	2025	☒ Correct ☐ Incorrect	11.2	13.1

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
120 PSI	120 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Dillon Payne	Service Technician (Signature)	Dillon Payne	Date	6/18/26
Customer (Print)		Customer (Signature)		Date	

CNP



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206208

Name **ROBERT ROGERS**

Address **136 PATRICK POINT
BLAIRSVILLE GA 30512**

Date: 6/15/26

Instructions: **DROP 250UG W/50G @2.499**

GC TO BURY - ANODE BAG

Order #: 514581

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to _____ year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Rinnai \$
Standard Vent Kit \$
Standard Install \$
Total \$

Contract Price

\$
\$
\$
\$

Tank Set

L P Gas /Gal 2.999

Gallons 50

FRCC \$9.79

Fuel Total 149.95

Tank Lease/YR 129.00

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250

Safety Inspection \$129.95

Total Labor

Total charges

Prepay Bal On Account

New Cust Special

L P Gas /Gal 2.499

Gallons 50

FRCC \$9.79

Fuel Total 124.95

1st yr Lease FREE

Tank Set Fee 20.00

Safety Inspection \$29.95

Total Labor

Total charges

Prepay Bal On Account

Safe Appliance Savings 474.57

Safe Appliance Rebate 400.00

TOTAL BALANCE DUE