

6/12/2026 3:01:03 PM

WORK ORDER

Thomas M Robinson

357 Black Ankle Creek Road
Cherry Log, GA 30522
(615) 202-5381

Customer #: 205345
Order #: 514935
Location #: 281329
Zone: B-010-THU-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 4-18-26 Final Hook Up of fireplace (per Mike) (615) 202-5381
CCOF Sm

Date Ordered: 6/12/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:

Last Service: 4/13/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 205345

Date: 6-18-26

Name: THOMAS M ROBINSON

Instructions: FINAL HOOK UP ON FIREPLACE CCOF SM
615-202-5381

Address: 357 BLACK ANKLE CREED RD

Order #: 514935

CHERRY LOG GA 30522

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Leaning F.P.	Water Heater	W. heater		
Manufacturer	Hearth, Home	Rinnia	Rinnia		
Model #	AVF160PF	RXP1607	REU-MB2530FF-US		
Serial #	MP099013932		RJBA.113214		
Burner/Combustion Chamber	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
1000	1568017	Good	Quality	2026	U.G.	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	LV3403TR9 08-2025	☒ Correct ☐ Incorrect		
2nd	MFC	1622E 18-12-2023	☒ Correct ☐ Incorrect	11.4	12.9

Piping System Leak Test:**Pressure Test:**

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
100 PSI	100 PSI	10 Mins	☒ Yes ☐ No	15 PSI	15 PSI	10 Mins	☒ Yes ☐ No
WC	WC	Mins					

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Alvin W. [Signature]	[Signature]	6-18-26
Customer (Print)	Customer (Signature)	Date
Customer not present	[Signature]	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 205345

Date: 4/7/26

Name: THOMAS M ROBINSON

Instructions: T/I RPX160 RECIRC. HANG&VENT

Address 357 BLQCK ANKLE CREEK ROAD

RUN LINE FROM TANK TO MANIFOLD

CHERRY LOG GA 30522

Order #: 492324

DESCRIPTION OF WORK

COMMENTS: Installed RPX160

SERVICED BY: AW / DP / CF

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
4-7-26	9:00	11:00	1.5 HR	100.00 ~~100.00/hr~~	INLCUED IN
		1.5 hr free		100.00 ~~100.00/hr~~	CONTRACT PRICE

FOR OFFICE USE ONLY

Performed leak check ☒ Yes ☐ No
 Gas check attached ☒ Yes ☐ No
 Leak check Initial AW

Start Pressure 80 End Pressure 80 Time Held 10 System OK yes

% in Tank

75

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.

* Signing agrees to 3 year contract for discount.

178302D159D346F...

CUSTOMER SIGNATURE

Retail Price		Contract Price	
RPX160 Rinnai	\$ 2556.00	\$ 2449.95	
Standard Vent Kit	\$ 393.95	\$ 0.00	
Standard Install	\$ 400.00	\$ 0.00	
Total	\$ 3349.95	\$ 2449.95	2449.95
Tank Set		New Cust Special	
L.P. Gas /Gal		L.P. Gas /Gal	
Gallons		Gallons	
FRCC	\$9.79	FRCC	\$9.79
Fuel Total		Fuel Total	
Tank Lease/YR		1st yr Lease	
Total Materials			
Sub-Total			3,223.19
Sales Tax			222.16
Tank Set Fee	\$250	Tank Set Fee	
Safety Inspection	\$129.95		\$29.95
Total Labor			50.00
Total charges			
Prepay Bal On Account			
Safe Appliance Savings			900.00
Safe Appliance Rebate			200.00
TOTAL BALANCE DUE			3,445.35