



PARTNERS PROPANE OF GA,
INC.
PO BOX 277
BUTLER, GA 31006
(478) 862-4644

Cust ID GREFRA
Account # 317
Invoice # S0014635
Invoice Date 7/14/2026

Sold To
FRANKIE GREENE
PO BOX 759
BUTLER, GA 31006-0759

Shipped To Location 1
FRANKIE GREENE
8 DIXON RD
BUTLER, GA 31006

Date 7/14/2026
Salesperson 6
PO #

Terms due upon receipt
Order Date
Ship Via

Quantity	Category	Description	Unit Price	Amount
85.00	12R50	1/2" COPPER TUBING	4.0000	\$340.00
		REGULAR SALES TAXABLE		27.20
10.00	38R50	3/8" COPPER TUBING	3.5000	\$35.00
		REGULAR SALES TAXABLE		2.80
30.00	58R50	5/8" Copper Tubing	5.5000	\$165.00
		REGULAR SALES TAXABLE		13.20
1.00	912PS12	Pigtail POL X POL 12"	0.0000	\$0.00
1.00	LV4403S	5 LB REGULATOR	65.0000	\$65.00
	R4			
		REGULAR SALES TAXABLE		5.20
1.00	48-8-12	1/2"X3/4" FI X Male Conn	5.0000	\$5.00
		REGULAR SALES TAXABLE		0.40
1.00	42-8	1/2" Flare Union	3.0000	\$3.00
		REGULAR SALES TAXABLE		0.24
4.00	40-6	3/8" Flare Nut	2.0000	\$8.00
		REGULAR SALES TAXABLE		0.64
6.00	40-8	1/2" Flare Nut	2.5000	\$15.00
		REGULAR SALES TAXABLE		1.20
6.00	40-10	5/8" Flare Nut	3.2500	\$19.50
		REGULAR SALES TAXABLE		1.58
1.00	39-10	5/8" SWIVEL NUT	7.3000	\$7.30
		REGULAR SALES TAXABLE		0.57
1.00	491002	3/4 Cutoff	15.0000	\$15.00
		REGULAR SALES TAXABLE		1.20
1.00	492012	1/2"X1/2" FIX Fem Cutoff	11.0000	\$11.00
		REGULAR SALES TAXABLE		0.88
2.00	45050	1/2" Black Tee	3.0000	\$6.00
		REGULAR SALES TAXABLE		0.48
4.00	45200	1/2 X Close Black Nipple	2.2500	\$9.00
		REGULAR SALES TAXABLE		0.72
1.00	48-10-8	5/8"X1/2" FI X Male Conn	4.7000	\$4.70
		REGULAR SALES TAXABLE		0.39
1.00	45070	1/2" Black Pipe Cap	1.1000	\$1.10
		REGULAR SALES TAXABLE		0.08
1.00	45010	1/2" Black 90 Deg Elbow	1.5000	\$1.50
		REGULAR SALES TAXABLE		0.14
1.00	48-8-8	1/2"X1/2" FI X Male Conn	2.8500	\$2.85
		REGULAR SALES TAXABLE		0.23
2.00	49-10-8	5/8"X1/2" FIXMale Elbow	4.9500	\$9.90
		REGULAR SALES TAXABLE		0.80



PARTNERS PROPANE OF GA,
INC.
PO BOX 277
BUTLER, GA 31006
(478) 862-4644

Cust ID GREFRA
Account # 317
Invoice # S0014635
Invoice Date 7/14/2026

Sold To
FRANKIE GREENE
PO BOX 759
BUTLER, GA 31006-0759

Shipped To Location 1
FRANKIE GREENE
8 DIXON RD
BUTLER, GA 31006

Date 7/14/2026
Salesperson 6
PO #

Terms due upon receipt
Order Date
Ship Via

Quantity	Category	Description	Unit Price	Amount
1.00	44-10-10-8	5/8X5/8X1/2 Flare Tee	6.7500	\$6.75
		REGULAR SALES TAXABLE		0.55
1.00	45051	3/4" Black Tee	6.0000	\$6.00
		REGULAR SALES TAXABLE		0.48
2.00	45226	3/4 X Close Black Nipple	2.5000	\$5.00
		REGULAR SALES TAXABLE		0.40
1.00	45071	3/4" Black Pipe Cap	2.1500	\$2.15
		REGULAR SALES TAXABLE		0.17
1.00	55-10	5/8"X5/8" Flare Elbow	5.5000	\$5.50
		REGULAR SALES TAXABLE		0.46
1.00	RE199EP	Rinnai 9.7 Water Heater	1,500.0000	\$1,500.00
		REGULAR SALES TAXABLE		120.00
1.00	MIVK-T-LW	Plumbing kit for rinnai	150.0000	\$150.00
		REGULAR SALES TAXABLE		12.00
1.00	42-8-6	1/2"X3/8" Flare Union	2.7000	\$2.70
		REGULAR SALES TAXABLE		0.23
1.00	45202	1/2"X2" Nipple	2.0000	\$2.00
		REGULAR SALES TAXABLE		0.16
1.00	48-6-8	3/8"X1/2" FI X Male Conn	2.5000	\$2.50
		REGULAR SALES TAXABLE		0.22
1.00	30-6	3/8"X3/8" FLARE CUTOFF	15.0000	\$15.00
		REGULAR SALES TAXABLE		1.20
1.00		PERF REBATE	-200.0000	(\$200.00)
2.00		LABOR	125.0000	\$250.00

Subtotal	\$2,471.45
GA TAYLOR CO TAX	\$193.82
HEADER	
Invoice Total	\$2,665.27
Total Due	\$2,665.27

PROPANE SAFETY INSPECTION

Account # 8361 Name BRITTANY GREENE Address [1] 4 DIXON RD City BUTLER
 State GA Zip 31006 Phone 4789570581 Date of Inspection 07/14/2026 Branch/Location Work Order #

Equipment Type	Water Heater	Furnace	Range		
Manufacturer	Rinnai	Trane	Frigidaire		
Year Manufactured					
Model #	Re199e	4ycc4060e1090aa	Fcrg3052bba		
Serial #	To.ua-159112	232011018I	vf40114239		
Fuel	Propane	Propane	Propane		
BTUs (Maximum Input)	199,000	90,000	64,000		
Manual Shutoff Valve	OK	OK	OK		
Sediment Trap	OK	OK	N/A		
Burner(s) Condition	OK	OK	OK		
Combustion Chamber Condition	OK	OK	OK		
Control/Pilot Safety System	N/A	OK Electronic	OK Electronic		
Venting System	OK	OK	OK		
Combustion Air	OK	OK	OK		
Taken Out of Svc or Operation (Tag #)	No	No	No		

CONTAINER CHECK	Serial #	Cust. Own	Container Type		Size	Tank %	Manufacturer	Mfr. Date	DOT		Container			Relief Valve			Fittings Leak Test
			ASME/ DOT	AG/UG/AGUG					Last Requal Date	Type	Found.	Loc.	Cond.	Cond.	Date	Cap	
	2sg073683	N	ASME	AGUG	250 wg		American Welding	2003	N/A		OK	OK	OK	OK	NV	OK	OK

PIPING	Material			Size	Protection	REGULATOR(S)	Mfr.		Model #	Date Code	Cond.	Vent Position	Protection
	1st Stg	2nd Stg	3rd Stg				1st Stg	2nd Stg					
	CT (Copper Tubing)	CT (Copper Tubing)		1/2	OK		REGO	REGO	Llv4403sr9	2026	OK	OK	OK
	CT (Copper Tubing)			5/8	OK				Lv4403b4	2025	OK	OK	OK

CSST TRACKING Bonded ☐ Yes ☐ No ☐ Unknown Jurisdictional Acct. ☐ Y ☒ N ☐ Unknown Gas Lines Capped ☐ Y ☒ N/A Heat Pump ☐ Y ☒ N

System Type	System Leak Check ☒ Entire System				Pressure Test				System Operation Tests			
	Initial/Start Pressure	End Pressure	Start Time	End Time	Start Pressure	End Pressure	Start Time	End Time	Flow Pressure Test	Lock-Up Pressure Test		
1st Stage	5 / 3 ☐ WC ☐ PSI	3 ☐ WC ☐ PSI	10:20	10:25		PSI		PSI		☐ WC ☐ PSI		☐ WC ☐ PSI
2nd Stage					8	PSI	8	PSI	10:00	10:15	10 ☐ WC ☐ PSI	11 ☐ WC ☐ PSI
						PSI		PSI			☐ WC ☐ PSI	☐ WC ☐ PSI
						PSI		PSI			☐ WC ☐ PSI	☐ WC ☐ PSI

Performed Sniff Test ☒ Y ☐ N Comments

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

I, ☐ Property Owner ☐ Tenant ☒ Authorized Representative, acknowledge that the individual performing the propane safety review informed me of the procedure and the outcome of the review; what was covered by the review and what was not covered; what repairs and/or alterations, if any, were made to the gas system or appliances; and options available for making recommended changes to my gas system. I further acknowledge that:

- I have informed the individual performing the propane safety review of all gas-burning appliances and gas lines on my property.
- I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas off at the tank.
- I have smelled the propane gas and can detect its odor.
- I have been told that the odorant giving propane its distinctive smell can fade or diminish in intensity.

In addition, I have been told that certain physical limitations or conditions might prevent me from smelling a gas leak.

- I have received customer safety information and been told to read it and share it with all family members.
- I am satisfied with the service work performed.
- I have been advised to install one or more gas and carbon monoxide detectors listed by Underwriters Laboratories (UL) as an additional measure of safety.

I have been provided the following additional safety materials:

- ☒ Propane Safety Booklet (PRC-005606 or PRC-101063)
- ☒ Important Propane Safety Information Brochure (PRC-003121 or PRC-101062)
- ☒ Carbon Monoxide Brochure (PRC-000075)

Tyler Robinson
 Service Technician Name - Print

 Service Technician Signature 07/14/2026 Date

BRITTANY GREENE
 Customer Name - Print
 Customer not available to sign 07/14/2026 Date
 Customer Signature