

✓

7/7/2026 10:54:14 AM

WORK ORDER

Cesar Castano

382 Pocaset Drive
Ellijay, GA 30540
(786) 447-7142

Customer #: 206337
Order #: 523354
Location #: 282576
Zone:
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 7/10/26 T/I 325ag w/260g @ 2.499 lines already ran call builder
678-431-5176 ccot-clt

Date Ordered:	Scheduled Date:	Est. Completion:	Start:	Stop:
---------------	-----------------	------------------	--------	-------

Name:	Last Service:	Last Tune Up:
Contract:	SC Renewal:	
Manufact:	Model:	
Notes:		
Instructions:		

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------

2



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206337

Name: CESAR CASTANO

Address: 382 POCASET DRIVE

ELLIJAY GA 30540

Date: 7/10/26

Instructions: T/I 325AG W/260G @ 2.499 LINES

ALREADY THERE CCOF-CLT

Order #: 523354

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove	kgset	~~kgset~~			
Manufacturer	Kitchen Aid					
Model #	KSC5700FS	LMVFPV				
Serial #	RC5010457	MP625041053				
Burner/Combustion Chamber	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
325	25H045253	Good	American	1997	AG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	3403TR9 08-2022	☒ Correct ☐ Incorrect		
2nd	Rego	3403B4 04-2025	☒ Correct ☐ Incorrect	11.3	13.3

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes ☐ No	15 PSI	15 PSI	10 Mins	☒ Yes ☐ No
WC	WC	Mins					

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date 7-10-26
Customer (Print)	Customer (Signature)	Date 7-10-26



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206337

Name CESAR CASTANO

Address 382 POCASET DRIVE

ELLIJAY GA 30540

Date: 7/10/26

Instructions: T/I 325AG W/260 @ 2.499 LINES

ALREADY RAN CCOF-CLT

Order #: 523354

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$	\$	
Standard Vent Kit \$	\$	
Standard Install \$	\$	
Total \$	\$	

Tank Set

New Cust Special

L.P. Gas /Gal 2.999	L.P. Gas /Gal 2.499	
Gallons 260	Gallons 260	
FRCC \$9.79	FRCC \$9.79	9.79
Fuel Total 779.74	Fuel Total 649.74	649.74
Tank Lease/YR 99.00	1st yr Lease FREE	FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee \$250	Tank Set Fee 20.00	20.00
Safety Inspection \$129.95	\$29.95	29.95
Total Labor		
Total charges		
Prepay Bal On Account		

Safe Appliance Savings	575.03
Safe Appliance Rebate	50.00

TOTAL BALANCE DUE