

VCLT

7/21/2026 10:21:14 AM

WORK ORDER

Brett Benson

1780 Ada St
Blue Ridge, GA 30513
(706) 633-8486

Customer #: 28495
Order #: 526809
Location #: 264871
Zone: B-015-FRI-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 7/22/26 C/C stove kit on site Call 706-633-7643 CCOF-CLT

Date Ordered: 7/21/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name: Heating System

Last Service: 4/14/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 28495

Date: 7/22/26

Name: BRETT BENSON

Instructions: C/C STOVE KIT ON SITE CCOF-CLT

Address: 1780 ADA ST

BLUE RIDGE GA 30513

Order #: 526809

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove					
Manufacturer	Hot Point					
Model #	RG135330DR38B					
Serial #	HD334190R					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
120	M2166690	Good	Trione	2021	AG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin Rego	3403	08-22	☒ Correct ☐ Incorrect	11.1	13.0
1st			☐ Correct ☐ Incorrect		
2nd			☐ Correct ☐ Incorrect		

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
120 PSI	120 PSI	10 Mins	☒ Yes ☐ No	15 PSI	15 PSI	10 Mins	☒ Yes ☐ No

Comments:

Customer Acknowledgment:

 I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print) Brandon Pyne	Service Technician (Signature) Brandon Pyne	Date
Customer (Print) Brett Benson	Customer (Signature) Brett Benson	Date 7-22-26



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 29495
Name BRETT BENSON
Address 1780 ADA ST
BLUE RIDGE GA 30513

Date: 5-22-26
Instructions: T/I 250 W/ 200G @ 2.499 CONNECT TO
LINES ALREEDY THERE. CCOF SM 706-633-7643
Order #: 502569

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$	\$
Standard Vent Kit \$	\$
Standard Install \$	\$
Total \$	\$

Tank Set

New Cust Special

L.P. Gas /Gal	2.999	L.P. Gas /Gal	2.499
Gallons	200	Gallons	200
FRCC	\$9.79	FRCC	\$9.79
Fuel Total	599.80	Fuel Total	499.80
Tank Lease/YR	99.00	1st yr Lease	FREE

Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee \$250	Tank Set Fee 20.00	20.00
Safety Inspection \$129.95	\$29.95	29.95
Total Labor		
Total charges		
Prepay Bal On Account		

Safe Appliance Savings 648.86

Safe Appliance Rebate 50.00

TOTAL BALANCE DUE