

VClt

C

7/27/2026 1:43:10 PM

WORK ORDER

Mark Auger

17 Pinhoti Pass
Ellijay, GA 30540
(706) 889-2480

Customer #: 204737
Order #: 527522
Location #: 280574
Zone: B-043-FRI-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 07/29/26 - RUN LINE TO W/HEATER AND HOOK UP -
ALREADY HUNG AND VENTED. RUN @35FT TO GEN AND
HOOK UP, RUN @50FT TO POOL HEATER AND HOOK UP -
CALL MATT 706-889-2480 - EMAIL INVOICE - CT

Date Ordered: 7/27/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
--------------------------------	------------------------	-------------------------	---------------	--------------

Name:

Last Service: 6/29/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 204737

Name: MARK AUGER

Address: 17 PINHOTI PASS

ELLIJAY, GA 30540

Date: 7/29/26

Instructions: RUN LINE TO W/HEATER HEATER, @35FT TO GE
GENERATOR AND HOOK UP, AND @50FT TO POOL HEATER
CALL MATT 706-889-2480 EMAIL INVOICE.

Order #: 527522

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	<u>Generator</u>	<u>Pool Heater</u>	<u>Hot Water H</u>			
Manufacturer	<u>Generac</u>	<u>Hayward</u>	<u>Nav</u>			
Model #	<u>G46004537</u>	<u>H-Series</u>	<u>NPE-240A2</u>			
Serial #	<u>3016719303</u>	<u>FDH0220202</u>	<u>2047C2590</u>	<u>669115</u>		
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
<u>500</u>	<u>2527725</u>	<u>Good</u>	<u>TRB</u>	<u>2025</u>	<u>LG</u>	<u>Good</u>

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	<u>Rego</u>	<u>LV3403TR4</u>	<u>04-25</u>	☒ Correct ☐ Incorrect	
2nd	<u>Rego</u>	<u>LV4403B66</u>	<u>05-26</u>	☐ Correct ☐ Incorrect	<u>11.2</u>

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
<u>100</u> PSI	<u>100</u> PSI	<u>10</u> Mins	☒ Yes	<u>15</u> PSI	<u>15</u> PSI	<u>10</u> Mins	☒ Yes
<u> </u> WC	<u> </u> WC	<u> </u> Mins	☐ No				☐ No

Pressure Test:

Comments: _____

Customer Acknowledgment:

 I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	<u>Alvin Wilcox</u>	Service Technician (Signature)	<u>[Signature]</u>	Date	<u>7-29-26</u>
Customer (Print)	<u>Mark Auger</u>	Customer (Signature)	<u>[Signature]</u>	Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 204737
Name Mark Auger
Address 17 Pinhoti Pass
Ellijay, GA. 30540

Date: 11/11/25

Instructions: Go 1st- T/I 500ug w/50G @2.599
Johnny will bury run yard lines and anode test
Roughin 7 lines. Call Matthew- 7068892480
Order #: 417828 email Invoice CT

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY
Performed leak check ☐ Yes ☐ No
Gas check attached ☐ Yes ☐ No
Leak check Initial _____
Start Pressure _____ End Pressure _____ Time Held _____ System OK _____

% in Tank

AMOUNT REC'D
\$ _____
☐ CASH ☐ CHECK # _____
☐ CREDIT CARD

EXP. DATE _____

* I have received the Consumer Safety information & material.
* I am satisfied with the work performed.
* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
* Signing agrees to _____ year contract for discount.

CUSTOMER SIGNATURE _____

Retail Price		Contract Price	
_____ Rinnai	\$ _____	\$ _____	
Standard Vent Kit	\$ _____	\$ _____	
Standard Install	\$ _____	\$ _____	
Total	\$ _____	\$ _____	

Tank Set		New Cust Special	
L.P. Gas /Gal	2.99	L.P. Gas /Gal	2.59
Gallons	50	Gallons	50
FRCC	\$9.79	FRCC	\$9.79
Fuel Total	149.95	Fuel Total	129.95
Tank Lease/YR	129	1st yr Lease	free
Total Materials			
Sub-Total			
Sales Tax			
Tank Set Fee	\$250	Tank Set Fee	20.00
Safety Inspection	\$129.95		\$29.95
Total Labor			
Total charges			
Prepay Bal On Account			
Safe Appliance Savings			487.33
Safe Appliance Rebate			200.00
TOTAL BALANCE DUE			