



INVOICE

No 11427 ✓

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Jason Williams</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>2159 Lynch Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-278-2461</u>	DATE COMPLETED	<u>8-3-26</u>
LOCATION		TERMS	

INSTRUCTIONS hook up water heater @ pool house

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rago LV340384 second stage regulator		59 95
31'	1/2" coated copper tubing	3 99	123 69
6	1/2" flare nut	1 60	9 60
2	1/2" x 1/2" male adapter	3 09	6 18
1	1/2" cut off valve		16 95
1	1/2" swivel		3 99
1	1/2" tee		4 59
1	1/2" x 3/4" female adapter		3 19

SERVICEMAN TO COMPLETE IN
PRESENCE OF CUSTOMER:1) STORAGE SYSTEM INSTALLED
IN COMPLIANCE WITH N.F.P.A.
PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN
COMPLIANCE WITH N.F.P.A.
PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

installed gas to
new water heater, regulator, gas line
& fittings, ran pressure check, 1.5'
& checked out water heaterTOTAL
MATERIAL:

228 14

TOTAL TIME HOURS

LABOR

600 00

THE ODOR CHARACTERISTICS HAVE
BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY

[Signature]

SUBTOTAL

SALES TAX

18 25

TOTAL DUE

846 39

CUSTOMER'S SIGNATURE

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE:	SIZE:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
S/N:	S/N:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
GALLONS OR READING:	GALLONS OR READING:	PRESSURE AS LEFT:	PRESSURE AS LEFT:

-GPA rebate 200.00
AMOUNT
RECEIVED \$ 646.39

RECEIVED
BY _____
DATE _____
SERVICES RECEIVED
BY _____

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 8/3/26
 Name Jason Williams Company Sikes Propane, Inc.
 Address 2159 Lynch Rd. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-278-2461 (Home) _____

Appliance Check

Appliance	water heater	generator	pool heater			
Manufacturer	Rinnai	Generac	Pentair			
Model #	RE140e	G00721010	460737			
Serial #	WD.4A-03 6819	3016576489	1117305170 2088			
BTL's	140,000	355,000	400,000			
Burner / Com. Chamber	ok	ok	ok			
Man. Shutoff / Sed. Trap	installed	existing	existing			
Control / Pilot Safety System	ok	ok	ok			
Venting System	ok	ok	ok			
Age	new	1yr.	8yrs.			
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
250	1233528	Quality Steel	2017	ok	ok	3B17	ok

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
140psi.	140psi.	10 min.	0
			Work Order 0

Piping Check

Materials	Size	Cover / Protection
coated copper	5/8" + 1/2"	ok

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
9 in. wc.	9 in. wc.	10 min.	0
			Work Order 0

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
First	Rego	05D2024 / LV4403TR9	u-c
Second	Rego	09D2024 / LV4403B66	down
Second	Rego	02C2024 / LV4403B66R	down
Second	Rego	07E2024 / LV3403BY	down

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.