



INVOICE

No 11438

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Tony Batchelor</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>1008 Springhill Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Alamo GA 30411</u>	DATE PROMISED	
PHONE	<u>229-457-4890</u>	DATE COMPLETED	<u>8-4-26</u>
LOCATION		TERMS	

INSTRUCTIONS run gas lines, set 120 gallon tank, install tankless water heater, & gas logs

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RE140e tankless water heater w/isolation valves, serial # WG-UA-077811		1150 00
1	Monassey 30" Highland Oak log set w/valh remote		1199 00
100	gallon of propane	2 99	299 00
92'	3/8" coated copper tubing	2 99	275 08
12'	1/2" coated copper tubing	3 99	47 88
1	1/2" cut off valve		16 95
1	3/8" cut off valve		12 95
4	1/2" flare nut	1 60	6 40
All	other gas fittings, thread sealant, stud guards, per fitting		39 20

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

ran all gas lines,

TOTAL MATERIAL

3046 46

set 120 gallon tank, installed tankless water heater & gas logs with remote, ran pressure check, lit & checked out appliances

TOTAL TIME

HOURS

LABOR

850 00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY

Dan [Signature]

SUBTOTAL

SALES TAX

243 72

TOTAL DUE

4140 18

X CUSTOMER'S SIGNATURE

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>120</u>	SIZE	START LOCK UP:	START LOCK UP:
S/N: <u>25A016051</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>100 gal</u>	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

-GPGA rebate 200.00
AMOUNT
3940.18

RECEIVED BY _____
DATE _____
SERVICES RECEIVED BY _____

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 8 / 4 / 26
 Name Tony Batchelor Company Sikes Propane, Inc.
 Address 1008 Springhill Rd. Call Taken By _____
 City Alama State GA Zip 30411 Telephone (Cell) 229-457-4890 (Home) _____

Appliance Check

Appliance	<u>water heater</u>	<u>gas logs</u>				
Manufacturer	<u>Rinnai</u>	<u>Hearth + Home</u>				
Model #	<u>RE140e</u>	<u>NB24PV-B</u>				
Serial #	<u>WG. 4A-07 7811</u>	<u>MP663007 767</u>				
BTU's	<u>140,000</u>	<u>36,000</u>				
Burner / Com. Chamber	<u>ok</u>	<u>ok</u>				
Man. Shutoff / Sed. Trap	<u>installed</u>	<u>installed</u>				
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>				
Venting System	<u>ok</u>	<u>ok</u>				
Age	<u>new</u>	<u>new</u>				
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>120</u>	<u>25A016051</u>	<u>American W.</u>	<u>1994</u>	<u>ok</u>	<u>ok</u>	<u>10-94</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>145 psi.</u>	<u>145 psi.</u>	<u>10 min.</u>	<u>⓪</u> N	<u>⓪</u> N

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2" + 3/8"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>9 in. wc.</u>	<u>9 in. wc.</u>	<u>10 min.</u>	<u>⓪</u> N	<u>⓪</u> N

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>Twin</u>	<u>Rego</u>	<u>05A2025 / LV404B.39</u>	<u>n-c</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.