



PARTNERS PROPANE OF GA,
INC.
PO BOX 277
BUTLER, GA 31006
(478) 862-4644

Cust ID GILNIC
Account # 8360
Invoice # S0014632
Invoice Date 8/10/2026

Sold To
NICK GILES
PO BOX 625
BUTLER, GA 31006

Shipped To Location 1
NICK GILES
1954 THOMASTON HWY
BUTLER, GA 31006

Date 8/10/2026

Terms due upon receipt

Salesperson 7

Order Date

PO #

Ship Via

Quantity	Category	Description	Unit Price	Amount
120.00	PP12CTS	1/2 POLY PIPE	0.5000	\$60.00
		REGULAR SALES TAXABLE		4.80
120.00	1430Y	TRACER WIRE	0.3000	\$36.00
		REGULAR SALES TAXABLE		2.88
1.00	RE199EP	Rinnai 9.7 Water Heater	1,500.0000	\$1,500.00
		REGULAR SALES TAXABLE		120.00
1.00	MIVK-T-LW	Plumbing kit for rinnai	150.0000	\$150.00
		REGULAR SALES TAXABLE		12.00
1.00	PCD09-SHS	Rinnai Pipe Cover	225.0000	\$225.00
		REGULAR SALES TAXABLE		18.00
1.00	45051	3/4" Black Tee	6.0000	\$6.00
		REGULAR SALES TAXABLE		0.48
1.00	45228	3/4 X 2" NIPPLE	2.0000	\$2.00
		REGULAR SALES TAXABLE		0.16
1.00	45071	3/4" Black Pipe Cap	2.1500	\$2.15
		REGULAR SALES TAXABLE		0.17
1.00	LV4403T R9	1st Stage 10# Regulator	0.0000	\$0.00
1.00	LV4403B4	2nd Stage Regulator	74.7800	\$74.78
		REGULAR SALES TAXABLE		5.99
1.00	3552335	MEC Regulator Bracket	5.1200	\$5.12
		REGULAR SALES TAXABLE		0.40
10.00	58R50	5/8" Copper Tubing	5.5000	\$55.00
		REGULAR SALES TAXABLE		4.40
2.00	45036	3/4" Black 90 St Elbow	4.5000	\$9.00
		REGULAR SALES TAXABLE		0.72
1.00	49-10-12	5/8"X3/4" FIXMale Elbow	6.5000	\$6.50
		REGULAR SALES TAXABLE		0.54
1.00	491002	3/4 Cutoff	15.0000	\$15.00
		REGULAR SALES TAXABLE		1.20
1.00	48-10-12	5/8X3/4 FI X Male Conn	4.2500	\$4.25
		REGULAR SALES TAXABLE		0.33
2.00	40-10	5/8" Flare Nut	3.2500	\$6.50
		REGULAR SALES TAXABLE		0.54
1.00	45226	3/4 X Close Black Nipple	2.5000	\$2.50
		REGULAR SALES TAXABLE		0.22
2.00	XR10B8S N36LZ	1/2"x1/2" Poly Riser 36"	50.0000	\$100.00



PARTNERS PROPANE OF GA,
INC.
PO BOX 277
BUTLER, GA 31006
(478) 862-4644

Cust ID GILNIC
Account # 8360
Invoice # S0014632
Invoice Date 8/10/2026

Sold To
NICK GILES
PO BOX 625
BUTLER, GA 31006

Shipped To Location 1
NICK GILES
1954 THOMASTON HWY
BUTLER, GA 31006

Date 8/10/2026 Terms due upon receipt
Salesperson 7 Order Date
PO # Ship Via

Quantity	Category	Description	Unit Price	Amount
		REGULAR SALES TAXABLE		8.00
1.00		LABOR	125.0000	\$125.00
1.00		TANK LEASE	72.0000	\$72.00
		REGULAR SALES TAXABLE		5.76
1.00		PERF REBATE	-200.0000	(\$200.00)

Subtotal	\$2,256.80
GA TAYLOR CO TAX	\$186.59
HEADER	
Invoice Total	\$2,443.39
 Total Due	 \$2,443.39



PROPANE SAFETY INSPECTION



Account # 8360 Name NICK GILES Address [1] 1954 THOMASTON HWY City BUTLER

State GA Zip 31006 Phone 7067187300 Date of Inspection 08/06/2026 Branch/Location Work Order #

Equipment Type	Water Heater				
Manufacturer	Rinnai				
Year Manufactured					
Model #	Re199e				
Serial #	wc.ua-029430				
Fuel	Propane				
BTUs (Maximum Input)	199,000				
Manual Shutoff Valve	OK				
Sediment Trap	OK				
Burner(s) Condition	OK				
Combustion Chamber Condition	OK				
Control/Pilot Safety System	OK Electronic				
Venting System	OK				
Combustion Air	OK				
Taken Out of Svc or Operation (Tag #)	No				

CONTAINER CHECK	Serial #	Cust. Own	Container Type		Size	Tank %	Manufacturer	Mfr. Date	DOT		Container			Relief Valve			Fittings Leak Test
			ASME/ DOT	AG/UG/AGUG					Last Requal Date	Type	Found.	Loc.	Cond.	Cond.	Date	Cap	
	2sg064872	N	ASME	AG	250 wg		American Welding	2003	N/A		OK	OK	OK	OK	NV	OK	OK

PIPING	Material		Size	Protection	REGULATOR(S)	Mfr.		Model #	Date Code	Cond.	Vent Position	Protection
	1st Stg	PE (Plastic)	1/2	OK		1st Stg	REGO	Lv4403lr9	2025	OK	OK	OK
						2nd Stg	REGO	Lv4403b4	2025	OK	OK	OK

CSST TRACKING	Bonded	☐ Yes ☐ No ☐ Unknown	Jurisdictional Acct.	☐ Y ☒ N ☐ Unknown	Gas Lines Capped	☐ Y ☒ N/A	Heat Pump	☐ Y ☐ N
---------------	--------	---	----------------------	---	------------------	--	-----------	---

System Type	System Leak Check ☒ Entire System					Pressure Test				System Operation Tests			
	Initial/Start Pressure	End Pressure	Start Time	End Time		Start Pressure	End Pressure	Start Time	End Time	Flow Pressure Test	Lock-Up Pressure Test		
1st Stage	10 / 8 ☐ WC ☒ PSI	8 ☐ WC ☒ PSI	9:30	9:35		30 PSI	30 PSI	9:15	9:25			☐ WC ☒ PSI	☐ WC ☒ PSI
2nd Stage	/ ☐ WC ☒ PSI	/ ☐ WC ☒ PSI				PSI	PSI			10	11	☐ WC ☒ PSI	☐ WC ☒ PSI
	/ ☐ WC ☒ PSI	/ ☐ WC ☒ PSI				PSI	PSI					☐ WC ☒ PSI	☐ WC ☒ PSI
	/ ☐ WC ☒ PSI	/ ☐ WC ☒ PSI				PSI	PSI					☐ WC ☒ PSI	☐ WC ☒ PSI

Performed Sniff Test	☒ Y ☐ N	Comments	Leak tested system; ;
----------------------	--	----------	-----------------------

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

I, ☐ Property Owner ☐ Tenant ☒ Authorized Representative, acknowledge that the individual performing the propane safety review informed me of the procedure and the outcome of the review; what was covered by the review and what was not covered; what repairs and/or alterations, if any, were made to the gas system or appliances; and options available for making recommended changes to my gas system. I further acknowledge that:

- I have informed the individual performing the propane safety review of all gas-burning appliances and gas lines on my property.
- I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas off at the tank.
- I have smelled the propane gas and can detect its odor.
- I have been told that the odorant giving propane its distinctive smell can fade or diminish in intensity.

In addition, I have been told that certain physical limitations or conditions might prevent me from smelling a gas leak.

- I have received customer safety information and been told to read it and share it with all family members.
- I am satisfied with the service work performed.
- I have been advised to install one or more gas and carbon monoxide detectors listed by Underwriters Laboratories (UL) as an additional measure of safety.

I have been provided the following additional safety materials:

- ☒ Propane Safety Booklet (PRC-005606 or PRC-101063)
- ☒ Important Propane Safety Information Brochure (PRC-003121 or PRC-101062)
- ☒ Carbon Monoxide Brochure (PRC-000075)

Brandon Rustin
Service Technician Name - Print

Service Technician Signature
08/06/2026
Date

NICK GILES
Customer Name - Print

Customer Signature
08/06/2026
Date