

- SALES
- SERVICE
- INSTALLATION

MODERN GAS
THE PROS IN PROPANE SINCE 1954

ENERGY FOR EVERYONE
propane

Ty / RT

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 899594	Date Written 8/04/26	Taken By: DT	Schedule Date 8/05/26	Date Completed 8/5/26
Branch - Customer No. 1-06413	Home 229 942-0508	Work	Time Started 1:13 A.M. P.M.	Time Completed 3:30 A.M. P.M.
Name PECAN GROVE DAIRY LLC #3	Cell	19S LFT JACKSON DAIRY MAT BARN WITH 250 ON RT @ DAIRY **H/WATER** LEAVE TICKET@ MAIN OFFICE Mngr Keith #386-208-2729		
Address 2620 S LEE ST	City AMERICUS, GA	State 31709	Zip	
Service Address 2923 JACKSON DAIRY RBACONTON, GA	31716			

Work to be performed:

replace water heater D-100L-199-3X BRADFORD WHITE
WATER HEATER WITH NEW ONE SHOULD BE HERE AROUND
LUNCH PECAN GROVE COST \$9,907.00 PLUS INSTALLATION
TAKE BLOCKS TO PUT IT ON

Work completed

Swapped out water
heater. 10' of vent
pipe needed to
extend the roof.

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
1	3/4" throw valve BF-T-100-034		33.01	1	MP 501007		21.95
*	Exhaust lid on tank 6" diameter			16	POB		61.60
*	Metal roof will need rubber boot.				Bradford White M # D100L1993X S # BD55061529 199 x BTU		9907.00
DR. RT. Rt. Seq. Rate Deposit							
Tank Make		Size 250	Serial B12424CH	Tank Percent		60%	
Single Stage	Regular Date	Reg. Condition	Mfr.	Model	Vent Pos.	Protected?	
TWO 1st							
STAGE 2nd							

Less Check		Flow Check		Lock-up Check		SHOP OR TRUCK SUPPLIES	16 50
Manometer Reading at Start 11 in	Manometer Reading After 10 minutes 11 in	Manometer Reading Under Load	Manometer Reading			MATERIAL TOTAL	10040 06
Central Heating	Water Heater	Range	Clothes Dryer			TRIP CHARGE	
Manufacturer	Bradford white					LABOR	510 00
Model No.	D100L1993X					SUB-LABOR Rebate	<200 00
Serial No.	BD55061529					PERMIT	
Sed. Trap Vent						SHIPPING/FREIGHT	
Fuel/BTU	000 199 000	N/A	N/A			Thank You	
AGE	New					SALES TAX	Exempt
Shut off Installed						TOTAL	10350 06
☐ CASH ☐ CHECK				RECEIVED BY Ty & Ryan & DT			
Work Completed by:				Date 8/5/26			
Customer Signature				Date 8-5-26			
I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY							

ANY UNUSED GAS PIPING OUTLETS INDOORS?

☐ YES ☐ NO

IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?

☐ YES ☐ NO

CUSTOMER AVAILABLE

☐ YES ☐ NO

CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE

☐ YES ☐ NO