

gate code
1005

7/7/2026 9:38:35 AM

WORK ORDER

James & Karen Bunnelle

437 Chestnut Ridge
Blue Ridge, GA 30513
(770) 633-8173

Customer #: 23476
Order #: 523321
Location #: 256545
Zone: B-010-THU-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 07/08/26 - GO 1ST PER MIKE - T/I 7.5 RIANNI - HAUL OFF
UNIT \$25.00 - CALL 770-633-8173 - CCOF - CT

Date Ordered: 7/7/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------------	------------------------	-------------------------	---------------	--------------

Name: Heating System

Last Service: 6/29/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 23476
Name: **JAMES & KAREN BUNNELLE**
Address: **437 CHESTNUT RIDGE**
BLUE RIDGE, GA 30513

Date: 7/8/26
Instructions: **GO 1ST! T/I 7.5 RINNAI W/3YR CONTRACT**
HAUL OFF OLD UNIT \$25 CALL 770-633-8173 CCOF
Order #: **523321**

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	W H					
Manufacturer	Rinnai					
Model #	REU-VC2528FFUD-US					
Serial #	PH-CA-121648					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
120	M0732941	Good	Trinity	2007	AG	Good

Regulator(s):

Manufacturer		Model	Regulator Date	Regulator Venting		Flow/Delivery Pressure	Lock-Up Pressure
Twin	Rego	404B34	12/24	☒ Correct	☐ Incorrect	11.4	13.2
1st				☐ Correct	☐ Incorrect		
2nd				☐ Correct	☐ Incorrect		

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes ☐ No	____ PSI	____ PSI	____ Mins	☐ Yes ☐ No
____ WC	____ WC	____ Mins					

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Customer (Print)	Customer (Signature)	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 23476

Date: 7/8/26

Name JAMES & KAREN BUNNELLE

Instructions: GO 1ST! T/I 7.5 RINNAI W/3YR CONTRACT

Address 437 CHESTNUT RIDGE
BLUE RIDGE, GA 30513

HAUL OFF OLD UNIT \$25 CALL 770-633-8173 CCOF
Order #: 523321

DESCRIPTION OF WORK

COMMENTS: Swaped out RL 7.5 for NEW RL.7.5

SERVICED BY: JCL / FS

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
	8:30	9:30	1.5 HR	100.00/hr	INCLUDED IN
				100.00/hr	CONTRACT PRICE

FOR OFFICE USE ONLY

Performed leak check ☒ Yes ☐ No
Gas check attached ☒ Yes ☐ No
Leak check Initial JCL

Start Pressure End Pressure Time Held System OK
110 110 10 Yes

% in Tank 58

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to 3 year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

7.5 Rinnai	\$1673.00	\$1299.95	
Standard Vent Kit	\$426.95	\$0.00	
Standard Install	\$400.00	\$0.00	
Total	\$2499.95	\$1299.95	1299.95

Tank Set

New Cust Special

L.P. Gas /Gal		L.P. Gas /Gal	
Gallons		Gallons	
FRCC	\$9.79	FRCC	\$9.79
Fuel Total		Fuel Total	
Tank Lease/YR		1st yr Lease	
Total Materials			1324.95
Sub-Total			
Sales Tax			91.00
Tank Set Fee	\$250	Tank Set Fee	
Safety Inspection	\$129.95		\$29.95
Total Labor			0
Total charges			
Prepay Bal On Account			

Safe Appliance Savings	1000.00
Safe Appliance Rebate	200.00

TOTAL BALANCE DUE

1415.95