

7/22/2026 9:51:58 AM

WORK ORDER

Keri Walling

32 Hope Drive
Blue Ridge, GA 30513
(404) 545-8658

Customer #: 206418
Order #: 526950
Location #: 282676
Zone: B-015-FRI-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 7/31/26 GO FIRST! T/I 250UG W/200G @2.499 Johnny to bury
- run lines 3x fireplace and stove - anode bag T/I monitor for
auto Call 404-542-8658 ccof - clt

T/I 3-Wall Timers - if compatible

Date Ordered: 7/22/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
--------------------------------	------------------------	-------------------------	---------------	--------------

Name:

Last Service:

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206418

Date: 7/31/26

Name: KERI WALLING

Instructions: T/I 250UG W/200G @2.499 JOHNNY TO BURY

Address: 32 HOPE DRIVE

RUN LINES 3X F/P STOVE ANODE BAG T/I MONITOR
FOR AUTO CCOF-CLT

BLUE RIDGE GA 30513

Order #: 526950

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove		log set		log set		log set
Manufacturer	GE		GE-16/20/24R-12(M)P		everwarm		everwarm
Model #	GGS500SV2SS		2021010		EW P02430NV		EW P02430NV
Serial #	DD1011120		*Peterson		P126345-01		P126343-04
Burner/Combustion Chamber	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☒ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☒ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☒ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☒ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	2SP003103	Good	American	2003	U.G.	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego LV3403TR	04-2026	☒ Correct ☐ Incorrect		
2nd	Rego LV3403B4	08-2025	☒ Correct ☐ Incorrect	11.7	13.4

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

 I acknowledge, by checking each of the following items, that:

- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☒ I have smelled propane gas and can detect its odor.
- ☒ I have been told to consider installing one or more gas detectors.
- ☒ I have received safety information and told to read it and share it with all family members.
- ☒ I am satisfied with the service work performed.

Service Technician (Print)	Brandon Payne	Service Technician (Signature)	Brandon Payne	Date	7-31-26
Customer (Print)	KERI WALLING	Customer (Signature)	Keri Walling	Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206418

Date: 7/31/26

Name KERI WALLING

Instructions: T/I 250UGW/200G @ 2.4999 JOHNNY

Address 32 HOPE DRIVE

TO BURY RUN LINES 3X F/P AND STOVE ANODE BAG CCOF-CL

BLUE RIDGE GA 30513

Order #526950

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

Retail Price

Contract Price

Rinnai \$

\$

Standard Vent Kit \$

\$

Standard Install \$

\$

Total \$

\$

Tank Set

New Cust Special

L.P. Gas /Gal 2.999

L.P. Gas /Gal 2.499

Gallons 200

Gallons 200

FRCC \$9.79

FRCC \$9.79

9.79

Fuel Total 599.80

Fuel Total 499.80

499.80

Tank Lease/YR 129.00

1st yr Lease FREE

FREE

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250

Tank Set Fee 20.00

20.00

Safety Inspection \$129.95

\$29.95

29.95

Total Labor

Total charges

Prepay Bal On Account

Safe Appliance Savings

575.03

Safe Appliance Rebate 50.00

TOTAL BALANCE DUE

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

* I have received the Consumer Safety information & material.

* I am satisfied with the work performed.

* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.

* Signing agrees to year contract for discount.

CUSTOMER SIGNATURE