

7/31/2026 9:02:54 AM

WORK ORDER

Darren Impemba

1617 Mountain Creek Hollow Road
Talking Rock, GA 30175
(754) 224-7930

Customer #: 206114
Order #: 528352
Location #: 282302
Zone: B-031-MON-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 8/4/26 Hook up 2 log sets run line to gas stove c/c stove Call
754-224-7930 CCOF-CLT *Kit on site*

Date Ordered:	Scheduled Date:	Est. Completion:	Start:	Stop:
---------------	-----------------	------------------	--------	-------

Name:

Contract:

Manufact:

Notes:

Instructions:

Last Service: 6/22/2026

SC Renewal:

Model:

Last Tune Up:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206114

Name: DARREN IMPEMBA

Address: 1617 MOUNTAIN CREEK HOLLOW ROAD

TALKING ROCK GA 30175

Date: 8/4/26

Instructions: HOOK UP 2 LOG SETS ON SITE C/CSTOVE

RUN LINE TO STOVE CCOF-CLT

Order #: 528352

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	stove	log set				
Manufacturer	Whirlpool	hearth homes				
Model #	KSGS33DSPA/BS24PVB					
Serial #	RF1718416	MP663006142				
Burner/Combustion Chamber	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
325	M2542409	Good	Triar	2025	UG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	MEC		☐ Correct ☐ Incorrect		
2nd	Rego	LV340364 07/2025	☒ Correct ☐ Incorrect	12.5	13.3

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Brandon Payne	Service Technician (Signature)	Brandon Payne	Date	8/4/26
Customer (Print)		Customer (Signature)		Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206114
Name DARREN IMPEMBA
Address 1617 MOUNTAIN CREEK HOLLOW ROAD
TALKING ROCK, GA 30175

Date: 6/12/26
Instructions: T/I 325UG W/50G@2.499G HOLE WILL BE
DUG. COVER UP. RUN YD LINE @25FT. CALL
754-624-7930 CCOF
Order #: 514064

DESCRIPTION OF WORK	
COMMENTS:	
SERVICED BY:	

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY	
Performed leak check	Yes ☐ No ☐
Gas check attached	Yes ☐ No ☐
Leak check	Initial ☐
Start Pressure	End Pressure Time Held System OK

Retail Price		Contract Price	
Rinnai	\$	\$	
Standard Vent Kit	\$	\$	
Standard Install	\$	\$	
Total	\$	\$	

Tank Set		New Cust Special	
L.P. Gas /Gal	2.999	L.P. Gas /Gal	2.499
Gallons	50	Gallons	50
FRCC	\$9.79	FRCC	\$9.79
Fuel Total	149.95	Fuel Total	124.95
Tank Lease/YR	129.00	1st yr Lease	FREE
Total Materials			
Sub-Total			
Sales Tax			
Tank Set Fee	\$250	Tank Set Fee	20.00
Safety Inspection	\$129.95		\$29.95
Total Labor			
Total charges			
Prepay Bal On Account			
Safe Appliance Savings		494.78	
Safe Appliance Rebate		50.00	
TOTAL BALANCE DUE			

AMOUNT REC'D
\$
☐ CASH ☐ CHECK #
☐ CREDIT CARD
#
EXP. DATE
* I have received the Consumer Safety information & material.
* I am satisfied with the work performed.
* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
* Signing agrees to _____ year contract for discount.
CUSTOMER SIGNATURE