

7/30/2026 12:42:54 PM

WORK ORDER

RICHARD KRAVCHUK

260 EVENING SHADE TR
MINERAL BLUFF, GA 30559
(678) 478-2051

Customer #: 20069

Order #: 528262

Location #: 252749

Zone: B-014-WED-

Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 7/31/26 T/I Rinnai 7.5 Call 678-463-4113 CCOF-CLT

Date Ordered: 7/30/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name: Heating System

Last Service:

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 20069

Date: 7/31/26

Name: RICHARD KRAVCHUK

Instructions: T/I RINNAI 7.5 CCOF CLT

Address: 260 EVENING SHADE TR
MINERAL BLUFF GA 30559

Order #: 528262

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	water Heater					
Manufacturer	Rinnai					
Model #	RL75					
Serial #	BB-CA-021 499					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M0415632	Good	Trinity	2004	Hg	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	Lv3403TR9 NV	☒ Correct ☐ Incorrect		
2nd	Rego	Lv4403 NV	☒ Correct ☐ Incorrect	11.1	12.2

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
90 PSI	90 PSI	10 Mins	☒ Yes	____ PSI	____ PSI	____ Mins	☐ Yes
____ WC	____ WC	____ Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☒ I have smelled propane gas and can detect its odor.
- ☒ I have been told to consider installing one or more gas detectors.
- ☒ I have received safety information and told to read it and share it with all family members.
- ☒ I am satisfied with the service work performed.

Service Technician (Print)	Alvin Viera	Service Technician (Signature)	[Signature]	Date	7-31-26
Customer (Print)	R KRAVCHUK	Customer (Signature)	[Signature]	Date	7-31-6



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 20069
Name RICHARD KRAVCHUK
Address 260 EVENING SHDE TRAIL
MINERAL BLUFF GA 30559

Date: 7/31/26
Instructions: T/I RINNAI 7.5
CCOF-CLT
Order #: 528262

DESCRIPTION OF WORK

COMMENTS: Installed 7.5

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
7-31-26	8:40 Am	10:00 Am	1.5HR	100.00/hr ~~100.00/hr~~	INCLUDED IN CONTRACT

FOR OFFICE USE ONLY

Performed leak check ☒ Yes ☐ No
Gas check attached ☒ Yes ☐ No
Leak check Initial AW

Start Pressure 90 End Pressure 90 Time Held 10 System OK YES

% in Tank

50

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to 3 year contract for discount.

[Signature]
CUSTOMER SIGNATURE

Retail Price

Contract Price

7.5 Rinnai	\$ 1673.00	\$ 1499.95	
Standard Vent Kit	\$ 426.95	\$ 0.00	
Standard Install	\$ 400.00	\$ 0.00	
Total	\$ 2499.95	\$ 1499.95	1499.95

Tank Set

New Cust Special

L.P. Gas /Gal		L.P. Gas /Gal	
Gallons		Gallons	
FRCC	\$9.79	FRCC	\$9.79
Fuel Total		Fuel Total	
Tank Lease/YR		1st yr Lease	
Total Materials			
Sub-Total			1,499.95
Sales Tax			105.00
Tank Set Fee	\$250	Tank Set Fee	
Safety Inspection	\$129.95		\$29.95
Total Labor			2
Total charges			
Prepay Bal On Account			

Safe Appliance Savings 1000.00

Safe Appliance Rebate 200.00

TOTAL BALANCE DUE

1,604.95