

7/30/2026 3:06:41 PM

WORK ORDER

Randy Day

994 Bradley Road
Blairsville, GA 30512
(706) 897-3892

Customer #: 206458
Order #: 528292
Location #: 282724
Zone: B-011-MON-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service *upright*

Description: 8/4/26 T/I 120 w/100g @3.599 lines are already there Call
706-897-3892 CCOF-CLT

Date Ordered: 7/30/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:

Contract:

Manufact:

Notes:

Instructions:

Last Service:

SC Renewal:

Model:

Last Tune Up:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206458

Name: RANDY DAY

Address: 994 BRADLEY ROAD

BLAIRSVILLE GA 30512

Date: 8/4/26

Instructions: T/I120 W/100G@ 3.599 LINES ARE ALREADY

THERE CCOF-CLT

Order #: 528292

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove Top					
Manufacturer	GE					
Model #	JGB366REK6SS					
Serial #	DZ22413BP					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
120	4BH240 557702	Good	Worthington	9/05	Good	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin	LV404B34 Rego	12/24	☒ Correct ☐ Incorrect	11.3	13.1
1st			☐ Correct ☐ Incorrect		
2nd			☐ Correct ☐ Incorrect		

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
100 PSI	100 PSI	10 Mins	☒ Yes ☐ No	_____ PSI	_____ PSI	_____ Mins	☐ Yes ☐ No
_____ WC	_____ WC	_____ Mins					

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☒ I have smelled propane gas and can detect its odor.
- ☒ I have been told to consider installing one or more gas detectors.
- ☒ I have received safety information and told to read it and share it with all family members.
- ☒ I am satisfied with the service work performed.

Service Technician (Print) Fernando Sando	Service Technician (Signature) 	Date 8/4/26
Customer (Print) ROBERT A AAMS	Customer (Signature) 	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206458

Date: 8/4/26

Name RANDY DAY

Instructions: T/I 120G UPRIGHT W/100G @ 3.599

Address 994 BRADLEY ROAD

LINES ARE ALREADY THERE CCOF-CLT

BLAIRSVILLE GA 30512

Order #: 528292

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$	\$
Standard Vent Kit \$	\$
Standard Install \$	\$
Total \$	\$

Tank Set

New Cust Special

L.P. Gas /Gal 3.599	L.P. Gas /Gal 3.599
Gallons 100	Gallons 100
FRCC \$9.79	FRCC \$9.79
Fuel Total 359.90	Fuel Total 359.90
Tank Lease/YR 99.00	1st yr Lease 99.00

Total Materials	
Sub-Total	
Sales Tax	
Tank Set Fee \$250	Tank Set Fee FREE
Safety Inspection \$129.95	\$29.95
Total Labor	
Total charges	
Prepay Bal On Account	

Safe Appliance Savings	350.00
Safe Appliance Rebate	50.00

TOTAL BALANCE DUE