

VC

8/3/2026 10:15:36 AM

WORK ORDER

David Paul

Lot 2A Clay's Way
Blue Ridge, GA 30513
(561) 859-4366

Customer #: 206024
Order #: 531300
Location #: 282179
Zone: B-015-FRI-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 08/05/26 - FINAL HOOK - DO FULL GAS CHECK PER ALVIN.
CALL HEATH 706-455-5547 - CCOF - CT

Date Ordered: 8/3/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
Name:	Last Service: 7/31/2026		Last Tune Up:	
Contract:	SC Renewal:			
Manufact:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206024

Name: DAVID PAUL

Address: LOT 2A CLAYS WAY

BLUE RIDGE, GA 30513

Date: 8/5/26

Instructions: FINAL HOOK - DO FULL GAS CHECK PER AW
CALL HEATH 706-455-5547 CCOF

Order #: 531300

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Log set	Log set	Water Heater		Stove	
Manufacturer	Everwarm	Everwarm	Hot A Novien		Samsung	
Model #	EW102430	EW102430	WPE15092		NV	
Serial #	10056479	10056446	2075B256104559		NV	
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☒ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☒ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☒ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☒ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M2601243	Good	Trinic	2026	Log	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	meo	1222 H	☒ Correct ☐ Incorrect		
2nd	Rego	4403y4	☒ Correct ☐ Incorrect	11.1	12.3

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Pressure Test:

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print) Alvin Wilcox	Service Technician (Signature) 	Date 8-5-26
Customer (Print) Customer not present	Customer (Signature) 	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206024

Name DAVID PAUL

Address LOT 2A CLAYS WAY

BLUE RIDGE GA 30513

Date: 6/30/26

Instructions: DROP 250UG GC TO BURY W/50G @2.499

ANODE BAG CALL 706-455-6408 CCOF-CLT

Order #: 516961

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Rinnai \$

Standard Vent Kit \$

Standard Install \$

Total \$

Contract Price

\$

\$

\$

\$

Tank Set

L.P. Gas /Gal 2.999

Gallons 50

FRCC \$9.79

Fuel Total 149.95

Tank Lease/YR 129.00

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250

Safety Inspection \$129.95

Total Labor

Total charges

Prepay Bal On Account

New Cust Special

L.P. Gas /Gal 2.499

Gallons 50

FRCC \$9.79

Fuel Total 124.95

1st yr Lease FREE

Tank Set Fee 20.00

\$29.95

Safe Appliance Savings

494.78

Safe Appliance Rebate 250.00

TOTAL BALANCE DUE